

UK Declaration of Conformity

LENZE SE, Hans-Lenze-Strasse 1, 31855 Aerzen GERMANY

declares under sole responsibility compliance of the products

Controllers of the series:

I/O system 1000

S.I. 2016 No. 1091:

EPM-S110, EPM-S120, EPM-S130, EPM-S131, EPM-S140, EPM-S150, EPM-S160,
EPM-S200, EPM-S201, EPM-S202, EPM-S203, EPM-S204, EPM-S205, EPM-S206, EPM-S207, EPM-S208, EPM-S209, EPM-S210,
EPM-S300, EPM-S301, EPM-S302, EPM-S303, EPM-S304, EPM-S305, EPM-S306, EPM-S307, EPM-S308, EPM-S309,
EPM-S310, EPM-S311, EPM-S312, EPM-S322,
EPM-S400, EPM-S401, EPM-S402, EPM-S403, EPM-S404, EPM-S405, EPM-S406, EPM-S408, EPM-S409,
EPM-S410, EPM-S411, EPM-S412, EPM-S413, EPM-S414, EPM-S415,
EPM-S500, EPM-S501, EPM-S502, EPM-S503, EPM-S504, EPM-S505,
EPM-S600, EPM-S601, EPM-S602, EPM-S603, EPM-S604, EPM-S606,
EPM-S620,
EPM-S640, EPM-S650,
EPM-S700, EPM-S701, EPM-S702, EPM-S7C2
EPM-S910, EPM-S911, EPM-S912

for all products the typecode my be followed by numbers, letters or points

S.I. 2016 No. 1091 & S.I. 2016 No. 1101:

EPM-S416

the typecode my be followed by numbers, letters or points

with the

Electrical Equipment (Safety) Regulations 2016

S.I. 2016 No. 1101

Applied designated standards:

**EN 61010-1:2010 + A1:2019 + AC:2019-04
EN IEC 61010-2-201:2021**

The Electromagnetic Compatibility Regulations 2016

S.I. 2016 No. 1091

Applied designated standards:

**EN 61000-6-2:2005 + AC:2005
EN IEC 61000-6-2:2019
EN 61000-6-4:2007 + A1:2011
EN IEC 61000-6-4:2019
EN61131-2:2007**

The Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012

S.I. 2012 No. 3032

Applied designated standards:

EN IEC 63000:2018

Authorised representative

LENZE Ltd., 6, Abbey Court Fraser Road Priory, Business Park, MK44 3WH Bedford

The safety instructions of the manual are to be considered.

According to the EMC Regulations, the listed devices are not independently operable products. Compliance of the directive requires the correct installation of the product, the observance of specific installation notes and product documentation. This was tested on specific system configurations.

These products are intended for installation in machines. Operation is prohibited until it has been determined that the machines in which these products are to be installed, conforms to the above mentioned Regulations.


Place / date

Chief Executive Officer (CEO)

Approval coordinator

Aerzen

18.08.2025



Dr. Marc Wucherer



i.V. Torsten Pieper